

Town: BARTLETT

EPA Id: NH 0162300

System Name:

ATTITASH WOODS CONDO ASSOC

Pop Served: 135

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400022	FLUORIDES	MCL VIOLATION	4.00000	4.20000000	06/11/2004	
400023	FLUORIDES	MCL VIOLATION	4.00000	4.50000000	08/08/2004	
500024	FLUORIDES	MCL VIOLATION	4.00000	4.60000000	11/30/2004	

EPA Id: NH 0162250

System Name:

BARTLETT PLACE

Pop Served: 72

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400007	FLUORIDES	MCL VIOLATION	4.00000	3.90000000	02/04/2005	

EPA Id: NH 0168460

System Name:

BEAR PEAK AT ATTITASH

Pop Served: 800

PWS Type: NON-TRANSIENT NON-COMMUNITY

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400007	FLUORIDES	MCL VIOLATION	4.00000	2.60000000	02/10/2005	

EPA Id: NH 0162340

System Name:

BEAR VILLAGE SOUTH

Pop Served: 30

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400015	FLUORIDES	MCL VIOLATION	4.00000	4.10000000	06/11/2004	07/08/2005
400016	FLUORIDES	MCL VIOLATION	4.00000	4.00000000	02/04/2005	

EPA Id: NH 0162180

System Name:

BLUEBERRY VILLAGE CONDOMINIUMS

Pop Served: 40

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400007	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	02/10/2005	

EPA Id: NH 0162220

System Name:

CHRISTMAS MOUNTAIN CONDOS

Pop Served: 203

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400012	FLUORIDES	MCL VIOLATION	4.00000	2.10000000	02/10/2005	

Town: BARTLETT

EPA Id: NH 0162350

System Name: GOODRICH PROPERTY OWNERS ASSOC

Pop Served: 175

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400019	FLUORIDES	MCL VIOLATION	4.00000	2.40000000	02/10/2005	

EPA Id: NH 0162090

System Name: LINDERHOF MOUNTAINSIDE

Pop Served: 663

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400026	FLUORIDES	MCL VIOLATION	4.00000	2.90000000	02/04/2005	
400027	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	23.00000000	05/23/2005	

EPA Id: NH 0162210

System Name: MOUNTAINSIDE AT ATTITASH

Pop Served: 167

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400005	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	32.50000000	09/03/2004	
400008	FLUORIDES	MCL VIOLATION	4.00000	3.50000000	02/04/2005	
500006	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	32.00000000	12/10/2004	

EPA Id: NH 0167080

System Name: MT ATTITASH SKI/AQUABOGGAN

Pop Served: 1000

PWS Type: NON-COMMUNITY TRANSIENT

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400004	COLIFORM (TOTAL COLIFORM RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	02/05/2004	07/16/2004

EPA Id: NH 0162270

System Name: NORDIC VILLAGE

Pop Served: 315

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400005	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/04/2005	

EPA Id: NH 0162050

System Name: NORTH LEDGE

Pop Served: 105

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400025	FLUORIDES	MCL VIOLATION	4.00000	2.70000000	02/10/2005	

Town: BARTLETT

EPA Id: NH 0162230

System Name: PARTRIDGE WOODS CONDOMINIUMS

Pop Served: 120

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400017	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	435.00000000	05/10/2004	
400018	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	651.00000000	05/10/2004	
400019	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	327.00000000	11/05/2004	
400020	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	526.00000000	11/05/2004	
400023	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/04/2005	
500021	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	281.00000000	12/10/2004	
500022	URANIUM /(MASS units in ug/L)	MCL VIOLATION	30.00000	460.00000000	12/10/2004	

EPA Id: NH 0162100

System Name: RIVERSBEND

Pop Served: 48

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400012	FLUORIDES	MCL VIOLATION	4.00000	4.30000000	03/31/2004	
400013	FLUORIDES	MCL VIOLATION	4.00000	4.60000000	06/11/2004	
400014	FLUORIDES	MCL VIOLATION	4.00000	4.70000000	08/12/2004	
500015	FLUORIDES	MCL VIOLATION	4.00000	4.50000000	11/19/2004	

EPA Id: NH 0162140

System Name: RIVERSIDE COBB FARM HO

Pop Served: 63

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400005	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/04/2005	

EPA Id: NH 0162290

System Name: ROCKY RIVER RESORT

Pop Served: 100

PWS Type: COMMUNITY SYSTEM

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400006	FLUORIDES	MCL VIOLATION	4.00000	4.30000000	01/26/2004	
400007	FLUORIDES	MCL VIOLATION	4.00000	4.85000000	05/28/2004	
400008	FLUORIDES	MCL VIOLATION	4.00000	4.40000000	08/04/2004	
500009	FLUORIDES	MCL VIOLATION	4.00000	4.40000000	11/19/2004	

EPA Id: NH 0162130

System Name: ROLLING RIDGE

Pop Served: 83

PWS Type: COMMUNITY SYSTEM

Town: BARTLETT**EPA Id: NH 0162130****System Name: ROLLING RIDGE****Pop Served: 83****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400014	BERYLLIUM	MCL VIOLATION	0.00400	0.01100000	03/10/2004	
400015	BERYLLIUM	MCL VIOLATION	0.00400	0.01100000	07/06/2004	
400019	BERYLLIUM	MCL VIOLATION	0.00400	0.00900000	01/10/2005	
400021	FLUORIDES	MCL VIOLATION	4.00000	4.00000000	02/04/2005	
500020	BERYLLIUM	MCL VIOLATION	0.00400	0.00900000	01/10/2005	

EPA Id: NH 0162020**System Name: SACO RIDGE WATER INC****Pop Served: 83****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400009	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	59.00000000	11/09/2004	
400010	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	52.00000000	11/09/2004	
400011	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	48.00000000	11/09/2004	
400012	FLUORIDES	MCL VIOLATION	4.00000	3.90000000	02/04/2005	
500013	COMPLIANCE GROSS ALPHA	MCL VIOLATION	15.00000	42.00000000	02/10/2005	

EPA Id: NH 0162410**System Name: STILLINGS GRANT****Pop Served: 83****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400002	FLUORIDES	MCL VIOLATION	4.00000	2.40000000	02/04/2005	

EPA Id: NH 0162240**System Name: THE SEASONS AT ATTITASH****Pop Served: 440****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400019	FLUORIDES	MCL VIOLATION	4.00000	3.60000000	02/04/2005	

EPA Id: NH 0162200**System Name: TOP NOTCH CONDOMINIUMS ASSOC****Pop Served: 163****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400014	FLUORIDES	MCL VIOLATION	4.00000	2.80000000	02/10/2005	

EPA Id: NH 0162310**System Name: WHISPERING BROOK****Pop Served: 30**

Town: BARTLETT**EPA Id: NH 0162310****System Name: WHISPERING BROOK****Pop Served: 30****PWS Type: COMMUNITY SYSTEM**

Vio Id	Contaminant	Violation Description	MCL	Result Mg/l	Awareness	Comp Achved
400002	FLUORIDES	MCL VIOLATION	4.00000	3.10000000	02/04/2005	

Description of Data Reported**PWS: Public Water System**

Town: Town, city or unincorporated place - political boundary in which the system is located.

EPA Id: Also known as PWS Id. State and Federal number assigned to track PWS.

System Name: Legal name of PWS.

Pop Served: The population served by PWS.

PWS Type: Type of PWS based on Federal Definition.

Community: Residential system capable of serving at least 25 residents.

Non-Community Non-Transient: Non-residential system capable of serving at least 25 of the same people 6 months a year.

Non-Community Transient: A system capable of serving water to at least 25 people 60 days a year.

Viol Id: The Federal Fiscal Year plus the violation identifier assigned by Environmental Services.

Contaminant: The contaminant and/or rule of which the PWS is in violation.

Violation Description: The type of violation.

Awareness: Date the state became aware of the MCL or TT violation.

MCL (Maximum Contaminant Level): The highest amount of a contaminant that the EPA allows in drinking water. MCLs are defined in milligrams per liter (Mg/l) (parts per million) unless otherwise specified.

Result: Chemical Monitoring (Phase I, II, IIB and V) Rules: The analytical result(s) that caused the MCL violation.

Bacteria (Total Coliform) Rule: PRESENT indicates an MCL violation. ie., coliform is present.

Lead and Copper Rule and Surface Water Treatment Rule: TT (Treatment Technique) Violation or failure to meet operational and/or system requirements under the rule.

Comp Achved: The date the PWS returned to compliance for the violation.

* The violations listed are based on both Env-WS300 "NH Drinking Water Rules" and 40 CFR Part 141-143 "National Primary Drinking Water Regulations, Secondary Drinking Water Regulations"

--- END OF REPORT ---